essentials







Weatherproof Socket Outlets & Enclosures

A comprehensive selection of weatherproof electrical accessory producs.

The polycarbonate construction makes the Aquip66 range a durable and long lasting heavy duty range of products.



Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com

essentials



Weatherproof Socket Outlets & Enclosures

Proc	duct Range		
Weat	Weatherproof Socket Outlets & Enclosures		
OA03	S5AG	1 Gang DP Switched Socket Outlet - IP66 Enclosure - Anthracite Grey	
OA0 3	86AG	2 Gang DP Switched Socket Outlet - IP66 Enclosure - Anthracite Grey	
OA5 0	01AG	1 Gang Accessory IP66 Unfurnished Enclosure - Anthracite Grey	
OA5 0	02AG	2 Gang Accessory IP66 Unfurnished Enclosure - Anthracite Grey	
OA03 OA50	B6AG D1AG	2 Gang DP Switched Socket Outlet - IP66 Enclosure - Anthracite Grey 1 Gang Accessory IP66 Unfurnished Enclosure - Anthracite Grey	



OA035AG



OA036AG



OA501AG



OA502AG

Errors & Omissions excluded. Specification is subject to change without notice. All Metal Clad Mounting Boxes are supplied 40mm as standard.

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com







Weatherproof Socket Outlets & Enclosures

Product Dimensional Drawings (mm)

Weatherproof Socket Outlets & Enclosures



OA035AG, OA501AG



OA036AG, OA502AG

Errors & Omissions excluded. Specification is subject to change without notice. All Metal Clad Mounting Boxes are supplied 40mm as standard.

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com

essentials



Weatherproof Socket Outlets & Enclosures

Technical Specification				
Weatherproof Socket Outlets & Enclosures				
Material Composition	IP66 Enclosure: Polycarbonate, Rubber Gasket, Brass Lugs			
	Socket: Urea Plate and Rear Housing, Brass Terminals			
	Mild Steel Earth Strap, Silver "on-lay" copper/brass contacts			
	Steel and Yellow Passivated Terminal Screws			
Enclosure - Accessory Size	1 Gang: Up to 86mm x 86mm, 2 Gang: Up to 146mm x 86mm			
Enclosure Accessory Depth	35mm Maximum			
Cable Size (035,036)	4 x 2.5mm ² or 2 x 4mm ²			
Cable Entry	20mm Knockouts (1 top/bottom, 2 either side & 1 in rear)			
Lockable Cover	Yes (Eyelet on cover and base)			
UV Stabilised Enclosure	Yes			
Ingress Protection	IP66			
Warranty	5 Years (Domestic)			
Standards	BS 1363-2: 1995 + A4: 2012			
	BS EN 60529: 1992 + A2: 2013			

Additional Information

Ensure that the mains supply is isolated before commencing installation and refer to the circuit diagram with the relevant product.

Bare earth cables must always be covered with appropriate sleeving and wired to the earth terminal. Supplied complete with rubber gasket which helps maintain the IP rating when installing on to uneven walls.

Errors & Omissions excluded. Specification is subject to change without notice. All Metal Clad Mounting Boxes are supplied 40mm as standard.

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com



EU DECLARATION OF CONFORMITY

- 1. Issuer Name
 Scolmore International Limited

 2. Issuer Address
 1 Scolmore Park, Landsberg,

 Lichfield Road Industrial Estate,
- 3. Object(s) of Declaration Aquip66 Range
 a. Group Sockets & Enclosures
 b. Models No. OA035AG, OA036AG, OA501AG, OA502AG
- 4. The object of the declaration described above is in conformity with the requirements of the following Legislations:

Tamworth, Staffordshire, B79 7XB

Document No	Title
2014/30/EC	EMC Directive
2014/35/EC	Low Voltage Directive

5. All products contained within the aforementioned comply with the relevant standards and requirements listed below.

BS 1363-2: 1995 + A4: 2012 BS EN 60529: 1992 + A2: 2013

6. I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2015.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of: Scolmore International Limited

Karl Rawlins - Senior Technical Support Engineer







Scolmore International Ltd 1 Scolmore Park: Landsberg Lichfield Road Industrial Estate Tamworth, Staffordshire B79 7XB

t: 01827 63454 f: 01827 63362 e: sales@scolmore.com w: www.scolmore.com

